

CVPCSD Monthly Report

November 2024

Daily average flow = 203 gpm

Daily Average Raw NTU = 2.3

Daily Average Finished NTU = .039

Water Plant –

- Standard maintenance.
- Had SCADA failure. Was able to reset
- Rain/storm event caused underdose. Harry was able to get the plant back running smooth.
- Dump run

Distribution –

- Repaired broken service line at Stevens.
- Begun Backflow testing. Will complete before end of month.
- Will complete valve exercising in December

Summary

- Trying to wrap up our operations for transfer to 49er Lab.
- 49er lab will come a couple times a week over the next month to go over plant and Distribution ops.