

CVPCSD Monthly Report

July 2024

Daily average flow = 507 gpm

Daily Average Raw NTU = 2.63

Daily Average Finished NTU = .025

Water Plant –

- Tim finished installing PC at plant. Might need to finish connecting Log me in to VPN.
- Had an issue with Log Me In due to Crowd Strike incident.
- Battled some NTU issues at the plant due to water quality and shorter filter runs.
- Power outage on 7/12
- Working with PCAPCD for permitting the generator that was replaced and permitting the existing generator at the water plant.
- Many issues with algae in the region (PCWA, Neighboring agencies). We have been cleaning the raw intake and streaming screens two times a day, otherwise plant can not get enough water through screens

Distribution –

- Starting LSL inventory
- Repaired water service at 2314 Ross ct

Summary

- Mostly just battled algae issues all month. Bad year.
- Battled power and connectivity issues with internet.
- Planning on Nocking out majority of LSL this month. Will finish hopefully mid September.

- Start Backflow testing and valve exercising in September and October.
- Have estimate for New chem feed pump
- Waiting on cost for chemical piping
- Will remove dried sludge from lagoons in Late September. Will get price quote for next meeting for tractor rental and bin hauls from Recology.