CIP list for CVPCSD - 2023-24					
Item	Description	cost	Total	year	Priority
Sed Basin Inspection/ work.	Concrete repair on applied channel, inspection of remainder of basin for cracks and weak points.	TBD-	??	2024/2025	1
Iwaki Pumps	Diaphragm pump for chem feed	660.58 each x 4	\$2500-3000	Jul-23	1
Raw WQ	New sample pump, hach 5300 turbidimter, pH probe	NTU-\$4k, pH \$1500, Pump \$500.	\$6-8k total,Plus SCADA programming	2023/24	1
Distribution valve replacements	replace stuck/broken valves as we find them though our first year exercising. Add new iso valves at key areas to minimize customer shutdowns during repairs. (info from Hydros)	As needed	tbd	Ongoing	1
Hydrant replacements	Upgrade old dry barrel hydrants to wet barrel	As needed	tbd	Ongoing	1
New Chem tanks	New chem tanks with bottom feed to fix air lock and priming issues. *** Replumbed post hypo tank to bottom feed and is working great so far. Hoping this can be a short term solution to new tanks. Will need to purchase tank stands.	\$1500-2000 each. Plumbing for retro fit around \$250 each	\$6k	2022/23	1
Filter 3 rehab/rebuild	TBD	TBD	??	2024/25 get info from consultant on rebuild.	2
Jib Crane inspection/ New crane	Current jib crane at upper plant needs inspection and hoist. Possible new foundation. For hoisting chemical drums.	TBD	Inspection in process	Possibly on hold	2
Sample stations (5)	WQ sample stations in the dist system. Removes the need to sample at customers house and hydrants.	Materials \$7000. Labor Est -\$6-10k.	\$13-17k total	2023/24	2
Hydrant construction meters for rent	Purchase a couple hydrant meters for contractors to use when they want water. Use local agencies as reference	\$3,600			3
Innerties With NID/PCWA	Possible innertie with NID and PCWA at strategic locations to aid in redundancy. Currently we only have one water source at the canal.			TBD	?
Scan system maps	Scan maps to have didgital record of historical maps	In process		2023/24	3
Tree work on					

TBD

2023/24

3

road and at

plant

TBD