

CVPCSD Monthly Report

September 2024

Daily average flow = 422 gpm

Daily Average Raw NTU = 3.33

Daily Average Finished NTU = .028

Water Plant –

- New stenner chemical feed pump requested. Discuss...
- New Chemical storage tanks requested. Discuss...
- At the beginning of the month leak at applied channel go much worse. Purchased ridge/flexible hose and fittings.
- Were able to fix leak from applied channel with gunite with Prestige Gunite. Will look at water proofing epoxy this fall/winter.
- Plant compressor stopped working. Buying a better compressor that can run longer durations without tripping off.
- Will sample plant before and after algaecide treatment.

Distribution –

- Lorang Bros. repaired service curb stops at 5223 Ponderex, 3633 Mary (and neighbor), 4080 Louis Ct (and neighbor service)
- Lead Service Line Inspections are almost complete. 30 more addresses then we are done. Will submit report to DDW before 10/16.

Summary

- Leak at Applied Channel fixed
- LSL's almost complete
- Backflow testing to start ASAP
- Valve exercising and hydrant flushing next
- Need to clean sludge out of reclaim tank in Oct/Nov